


Power Quality and Energy Measurement PEM555



Power Quality and Energy Measurement

PEM555



Device features

- Accuracy class according to IEC 62053-22: 0.5 S
- Measured quantities
 - Phase voltages U_{L1} , U_{L2} , U_{L3} in V
 - Line conductor voltages U_{L1L2} , U_{L2L3} , U_{L3L1} in V
 - Phase currents I_1 , I_2 , I_3 in A
 - Neutral current (calculated) I_0 in A
 - Neutral current (measured) I_4 in A
 - Frequency f in Hz
 - Phase angle for U and I in $^\circ$
 - Power per phase conductor S in kVA, P in kW, Q in kvar
 - Total power S in kVA, P in kW, Q in kvar
 - Displacement factor $\cos(\varphi)$
 - Power factor λ
 - Active and reactive energy import in kWh, kvarh
 - Active and reactive energy export in kWh, kvarh
 - Voltage unbalance in %
 - Current unbalance in %
 - Harmonic distortion (THD) for U and I
 - k-Factor for I
- Programmable setpoint monitoring
- LED pulse outputs for active and reactive energy
- Modbus RTU and Modbus TCP
- 3 digital outputs
- Requirements of energy and current for particular time frames
- Peak demands with timestamps
- Individual, current/voltage harmonics up to the 31st harmonic
- Minimum and maximum values
- Waveform recording (6.4 kHz)
- Data recorder
- High-resolution waveform recording
- Detection of transient events

Product description

The digital universal measuring device PEM555 is suited for measuring and displaying electrical quantities of a public electricity network. The PEM555 is able to perform current, voltage, energy consumption and performance measurements as well as displaying individual current/voltage harmonics for assessment of the power quality. The accuracy of active energy measurements corresponds to class 0.5 S in accordance with the requirements of DIN EN 62053-22 (VDE 0418 Part 3-22). The current inputs are connected via external .../1 A or .../5 A measuring current transformers.

Typical application

- As a compact device for front panel mounting, the PEM555 is a replacement for analogue indicating instruments
- Typical application in low and medium-voltage networks (via measuring voltage transformer)
- Power quality monitoring
- Collection of relevant data for energy management
- Cost allocation of energy consumption
- High-resolution waveform recording allow analysis of power quality phenomena

Description of function

- Sampling rate of the measuring channels: 6.4 kHz
- Calculation of the total harmonic distortion THD_U/THD_I: harmonics up to the 31st harmonic
- Individual current/voltage harmonics
- Password protection
- Clamp mechanism, no tools required
- History memory for minimum and maximum values of current, voltage, energy, power rating etc. for each month
- Inputs and outputs:
 - 3 digital outputs, 6 digital inputs
 - 9 user-programmable setpoints (response values, response delay 0...9999 seconds)
 - System protocol: 64 events, setup changes, setpoint alarming, DI status changes, DO switching operations
- Communication:
 - Galvanically isolated RS-485 interface (1,200 bis 19,200 bit/s)
 - Modbus-RTU protocol
 - Modbus TCP (10/100 Mbit/s)


Standards

The universal measuring device for Power Quality and Energy Measurement PEM555 was developed in accordance with the following standards: DIN EN 62053-22 (VDE 0418 Part 3-22), DIN EN 61557-12 (VDE 0413-12)

Features

	PEM555
RS-485	■
Modbus TCP	■
Digital inputs	6
Digital outputs	3
Sampling rate	6.4 kHz
THD calculation and harmonics	31.
On-board memory	2 MB
Detection of transients	■


Operating elements



- 1 - Pulse LED: kWh
- 2 - Pulse LED: kvarh
- 3 - Display
- 4 - "V/I" button: Selection (in the menu)
- 5 - "POWER" button: Up (in the menu)
- 6 - "HARMONICS" button: Down (in the menu)
- 7 - "ENERGY" button: OK (in the menu)


Press the "ENERGY" button > 1.5 s to enter/leave the Setup menu.

Example for system set-up



NSHV = Low-voltage main distribution board

Wiring diagram




- 1 - Connection RS-485 bus
- 2 - Supply voltage. Power protection by a 6 A fuse, quick response. If being supplied from an IT system, both lines have to be protected by a fuse.
- 3 - Digital inputs
- 4 - Digital outputs (N/O contacts)
- 5 - Measuring voltage inputs
- 6 - Connection to the system to be monitored: The measuring leads should be protected by appropriate fuses.
- 7 - Connection Modbus TCP

Connection diagram voltage inputs


Three-phase 4-wire system (TN, TT, IT systems)

The PEM can be used in three-phase 4-wire systems, independent of the type of distribution system (TN, TT, IT system).




Three-phase 3-wire system

The PEM can be used in three-phase 3-wire systems.



Connection via voltage transformers

The coupling via measuring voltage transformers allows the use of a measuring device in medium and high voltage systems. The transformation ratio in PEM555 can be adjusted (1...10000).



Technical data
Insulation co-ordination
Measuring circuit

Rated insulation voltage	300 V
Overtoltage category	III
Pollution degree	2

Supply circuit

Rated insulation voltage	300 V
Overtoltage category	II
Pollution degree	2

Supply voltage

Rated supply voltage U_S	95...250 V
Frequency range of U_S	DC, 44...440 Hz
Power consumption	≤ 11 VA

Measuring circuit
Measuring voltage inputs

$U_{L1-N, L2-N, L3-N}$	230 V
	400 V (only -451, -455)
$U_{L1-L2, L2-L3, L3-L1}$	400 V
	690 V (only -451, -455)
Measuring range	10...120 % U_n
Rated frequency	45...65 Hz
Internal resistance (L-N)	> 500 k Ω

Measuring current inputs

External measuring current transformer should at least comply with accuracy class 0.5 S

Burden	n.A., internal current transformers
Measuring range	0.1...120 % I_n
PEM555/PEM555-455	
I_n	5 A
Measuring current transformer ratio	1...6000
Accuracy class according with 5 A measuring current transformer	0.5
Accuracy class according with 1 A measuring current transformer	1
PEM555-251/PEM555-451	
I_n	1 A
Measuring current transformer ratio	1...30000
Accuracy class according with 1 A measuring current transformer	0.5

Accuracies (of measured value/of full scale value)

Phase voltage $U_{L1-N}, U_{L2-N}, U_{L3-N}$	± 0.2 % of measured value.
Current	± 0.2 % of measured value + 0.05 % of full scale value.
Neutral current I_4	0.5 % of full scale value
Frequency	± 0.02 Hz
Phase position	± 1°
Active energy measurement according to	DIN EN 62053-22 (VDE 0418 Part 3-22)
r.m.s. voltage measurement according to	DIN EN 61557-12 (VDE 0413-12), chapter 4.7.6
r.m.s. phase current measurement according to	DIN 61557-12 (VDE 0413-12), chapter 4.7.5
Frequency measurement according to	DIN EN 61557-12 (VDE 0413-12), chapter 4.7.4

Interface

Interface/protocol	RS-485, Modbus RTU
Baud rate	1.2...19.2 kbits/s
Cable length	0...1200 m
Shielded cable (shield connected to terminal SH on one side)	recommended: J-Y(St)Y min. 2x0.8

Interface/protocol	Ethernet, Modbus TCP
Baud rate	100 Mbits/s

Switching elements

Outputs	3 N/O contacts
Operating principle	N/O operation
Rated operational voltage	AC 230V DC 24V AC 110V DC 12V
Rated operational current	5 A 5 A 6 A 5 A
Minimum contact rating	1 mA at AC/DC ≥ 10 V
Inputs	6 electrically separated digital inputs
I_{min}	2.4 mA
U_{DI}	DC 24 V

Environment/EMC

EMC	DIN EN 61326-1
Operating temperature	-25...+55 °C
Climatic class acc. to DIN EN 60721	
Stationary use	3K5
Classification of mechanical conditions acc. to DIN EN 60721	
Stationary use	3M4
Height	to 4000 m

Connection

Connection	screw-type terminals
------------	----------------------

Other


Degree of protection, installation	IP20
Degree of protection, front	IP52
Documentation number	D00016
Weight	≤ 1100 g

Ordering information

Interface	Nominal system voltage	Current input	Type	Art. No.
	3(N)AC			
RS-485/Ethernet	400/230 V	5 A	PEM555	B 9310 0555
		1 A	PEM555-251	B 9310 0556
	690/400 V	5 A	PEM555-455	B 9310 0557
		1 A	PEM555-451	B 9310 0558


Dimension diagram

Dimensions in mm



Panel cut-out

Dimensions in mm



Bender GmbH & Co. KG

P.O. Box 1161 • 35301 Gruenberg • Germany
 Londorfer Strasse 65 • 35305 Gruenberg • Germany
 Tel.: +49 6401 807-0 • Fax: +49 6401 807-259
 E-Mail: info@bender.de • www.bender.de



BENDER Group